

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load, Operating forces, Mechanical properties



Test Report

NO. 11-001449-PR01

(PB-A01-0203-en-01)

Client KM-OKNO S.C. KLESZCZ BOGUSLAW
KLESZCZ EWA
Borowa 171
39-215 Czarna
Poland

Product Window unit

Designation ALUPLAST IDEAL 4000

Performance-relevant product details PVC-U/white

Overall dimensions (WxH) 1560 mm x 2100 mm

Special features -/-

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12046-1:2000-02

EN 12211:2000-06

EN 14608:2004-06

EN 14609:2004-06

Correspond/s to the national standard/s (e.g. DIN EN)

Darstellung



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 5A

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C2 / B2

Operating forces according to EN 13115:2001-07



Class 1

Mechanical properties according to EN 13115:2001-07



Class 4

Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 31 pages.

ift Rosenheim

29. July 2011

Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
Building Components

Herbert Hageneder, Dipl.-Ing. (FH)
Operating Testing Officer
Tightness & Wind Load